

Stand-Alone Wind Energy Conversion System By Using Pitch Control Technique

N.Netaji Gandhi¹ T.SantoshKumar² V.Vijay Bhaskar³ S.Venu madhav⁴

1.Associate Professor in EEE dept., Holy Mary Institute of Tech & Science, R.R.Dist, Telangana, India

2,3,4.Assistant Professor in EEE dept, Holy Mary Institute of Tech & Science, R.R.Dist, Telangana, India

Abstract- The major source of power is from the conventional sources only. Some of the conventional sources of energies like thermal energy is produced from the fossil fuel coal which are depleting and is only limited to 2030. Renewable sources of energies are Solar, Wind, Biomass, etc hold bright prospect for the future. Wind industry has made rapid strides in the recent years. In order to ensure continuous supply of power suitable storage technology is used as backup. In this paper, the sustainability of a 4-kW hybrid of wind and battery system is investigated for meeting the requirements of a 3-kW stand-alone dc load representing a base telecom station. A charge controller for battery bank based on turbine maximum power point tracking and battery state of charge is developed to ensure controlled charging and discharging of battery. The mechanical safety of the WECS is assured by means of pitch control technique. Both the control schemes are integrated and the efficacy is validated by testing it with various load and wind profiles in MATLAB/SIMULNIK.

Index Terms— MPPT, pitch control, state of charge (SoC),

I. INTRODUCTION

Renewable energy sources including wind power offer a feasible solution to distributed power generation for isolated communities where utility grids are not available. In such cases, stand-alone wind energy systems can be considered as an effective way to provide continuous power to electrical loads. One of the most promising applications of renewable energy generation lies in the development of power supply systems for remote communities that lack an economically feasible means of connecting to the main electrical grid. For isolated settlements located far from a utility grid, one practical approach to self-sufficient power generation involves using a wind turbine with battery storage to create a stand-alone system. Stand-alone wind energy systems often include batteries, because the available wind does not always produce the required quantities of power. If wind power exceeds the load demand, the surplus can be stored in the batteries. The function of an electrical generator is providing a means for energy conversion between the mechanical torque from the wind rotor turbine, as the prime mover, and the local load or the electric grid. For the installation of wind energy MNRE scheme (The Ministry of New & Renewable energy) has introduced to aware more and more people about this technology, government also gives incentives in order to promote wind energy. Wind is air in motion; this is actually derived from solar energy. About 2% of total solar flux that reaches the earth's surface is transformed into wind energy due to uneven heating of atmosphere. This kinetic energy of wind is used to gain the rotational motion of wind turbine which is coupled with an electrical generator to supply over a region acting as standalone or supplying power to a grid. An actual WECS (Wind energy conversion system) be considered as follow [1] which can be used in two different ways: Isolated standalone system and Grid connected system. Figure 1 shows Isolated Standalone system which is used to provide energy to small scale industries or towns located in remote. The wind turbine is connected with the permanent magnet synchronous generator to extract electrical energy from wind in the form of KE – ME – EE. This electrical energy is fluctuating by the deviation of wind. Wind is not a constant wave. Diode rectifier is used to convert the PMSG output AC voltage into DC voltage. The rectifier filters are used to filter DC voltage and it is given to the inverter. The inverter is used to convert the DC voltage into constant AC voltage to connect with grid by using controllers

areas.




Fig. 1. Standalone wind energy system. Whereas Grid connected system leads to increased energy efficiency, increases support and reliability of system. Due to a relatively low cost of electricity production [2] wind energy is considered to be one of the potential sources of clean energy for the future [3].

II. OVERVIEW

A detailed comparison between asynchronous and synchronous generators for wind farm application is made in [4]. The major advantage of asynchronous machine is that the variable speed operation allows extracting maximum power from WECS and reducing the torque fluctuations [5]. Induction generator with a lower unit cost, inherent robustness, and operational simplicity is considered as the most viable option as wind turbine generator (WTG) for off grid applications [6].

However, the induction generator requires capacitor banks for excitation at isolated locations. The excitation phenomenon of self-excited induction generator (SEIG) is explained in [5]–[7]. The power output of the SEIG depends on the wind flow which by nature is erratic. Both amplitude and frequency of the SEIG voltage vary with wind speed. Such arbitrarily varying voltage when interfaced directly with the load can give rise to flicker and instability at the load end. So, the WECS are integrated with the load by power electronic converters in order to ensure a regulated load voltage [8].

III. HYBRID WIND-BATTERY SYSTEM FOR AN ISOLATED DC LOAD

The proposed hybrid system comprises of a 4-kW WECS and 400 Ah, C/10 lead acid battery bank. The system is designed for a 3-kW stand-alone dc load. The layout of the entire system along with the control strategy is shown in Fig. 1.

IV. STAND-ALONE HYBRID WIND- BATTERY SYSTEM CONTROL STRATEGY


The wind flow is erratic in nature. Therefore, a WECS is integrated with the load by means of an ac–dc–dc converter to avoid voltage flicker and harmonic generation. The control scheme for a stand-alone hybrid wind-battery system includes the charge controller circuit for battery banks and pitch control logic to ensure WT operation within the rated value. The control logic ensures effective control of the WECS against all possible disturbances.

A. Charge Controller for the Battery Bank

The development of charge controller circuit for a 400 Ah, C/10 battery bank using a dc–dc buck converter in MATLAB/SIMULINK platform. Generally, the batteries are charged at C/20, C/10, or C/5 rates depending on the manufacturer's specification where C specifies the Ah rating of battery banks. So, the battery bank system considered in the design can be charged at 20, 40, or 80 A. But, in this paper, C/10 rate (i.e., 40 A) for battery charging is chosen. However, the current required for charging the battery bank depends on the battery SoC.

B. Control Strategy

The implementation of the charge control logic as shown in Fig. 2 is carried out by three nested control loops. The outer most control loop operates the turbine following MPPT logic with battery SoC limit. To implement the MPPT logic, the actual tip speed ratio (TSR) of turbine is compared with the optimum value. The error is tuned by a PI controller to generate the battery current demand as long as the battery SoC is below the CC mode limit. Beyond this point, the SoC control logic tries to maintain constant battery charging voltage. This in turn reduces the battery current demand and thus prevents the battery bank from overcharging. The buck converter inductor current command is generated in the intermediate control loop. To design the controller, it is essential to model the response of the battery current (I_b) with respect to the inductor current (I_L).



maximum of C/10 rating of the battery. The battery charging current command has a minimum limit of zero. In case the wind speed is insufficient to supply the load even with zero battery charging current the inductor current reference is frozen at that particular value and the balance load current is supplied by the battery.

B. CV Mode of Battery Charging

In the CC mode, the battery voltage and SoC rise fast with time. However, the charge controller should not overcharge the batteries to avoid gasification of electrolyte [14]. As a result, once the battery SoC becomes equal to the reference SoC the controller must switch over from CC mode to CV mode. In CV mode, the battery charging voltage is determined from the buck converter output voltage (V_o).

C. Pitch Control Mechanism

If the WT is allowed to operate over the entire range of wind speed without implementation of any control mechanism, the angular speed of the shaft exceeds its rated value which may lead to damage of the blades. So, it is very much essential to control the speed and power at wind speeds above the rated wind speed. This is achieved by changing the pitch angle of the blade. Such a mechanism is referred to as the pitch control of WT.

D. Pitch Control Scheme

The pitch control scheme is shown in Fig. 7. As seen the p.u. value of each input is compared with 1 to calculate the error. The errors are tuned by PI controller. The “MAX” block chooses the maximum output from each PI controller which is then passed on to a limiter to generate the pitch command for the WT.

VI.SIMULATION RESULTS

Fig. 4. Load power variation




Fig. 5step variation of wind speed



Fig. 6 Battery current variation




Fig. 7 Inductor current





Fig.8.Load power of wind turbine

- [4] M. T. Ameli, S. Moslehpur, and A. Mirzale, "Feasibility study for replacing asynchronous generators with synchronous generators in wind farm power stations," in Proc. IAJC – IJME, Int. Conf. Eng. Technol., Music City Sheraton, Nashville, TN, US, ENT paper 129Nov. 17–19, 2008.
- [5] G. K. Singh, "Self excited generator research—

Fig. 9 battery voltage




Fig. 10 load voltage

III. CONCLUSION

In this a hybrid wind-battery system is chosen to supply the desired load power. To mitigate the random characteristics of wind flow the WECS is interfaced with the load by suitable controllers. The control logic implemented in the hybrid set up includes the charge control of battery bank using MPPT and pitch control of the WT for assuring electrical and mechanical safety. The charge controller tracks the maximum power available to charge the battery bank in a controlled manner. The hybrid wind-battery system along with its control logic is developed in MATLAB/SIMULINK and is tested with various wind profiles. The outcome of the simulation experiments validates the improved performance of the system.



REFERENCES

- [1] The Modeling and Simulation of Wind Energy Based Power System using MATLAB. International journal of power system Operation and Energy Management, ISSN (PRINT): 2231-4407, Volume -1, Issue-2, 2011.
- [2] R. D. Richardson and G. M. Mcnerney, "Wind energy systems," Proc. IEEE, vol. 81, no. 3, pp. 378–389, Mar. 1993.
- [3] R. Saidur, M. R. Islam, N. A. Rahim, and K. H. Solangi, "A review on global wind energy policy," Renewable Sustainable Energy Rev., vol. 14, no. 7, pp. 1744–1762, Sep. 2010. A survey," Electric Power Syst. Res., vol. 69, no. 2/3, pp. 107–114, 2004. R. C. Bansal, "Three-phase self-excited induction generators: An overview," IEEE Trans. Energy Conversion., vol. 20, no. 2, pp. 292–299, Jun. 2005.



NETAJI GANDHI received the Diploma in **Electrical and Electronics Engineering** from Govt. Polytechnic College Nizamabad, Andhra Pradesh in the year 2004, **B.Tech.** degree in **Electrical and Electronics Engineering** from **JNTU-Hyderabad**, Andhra Pradesh, India in the year 2008, and **M.Tech** from **IIT-Roorkee**, India in the year 2010. He has vast teaching experience of nearly 06 years in university as well as in engineering colleges. He is currently working as Associate Professor in Holy Mary Institute of Technology and Science, Bogaram (V), R.R. Dist, Hyderabad, Andhra Pradesh, India in the Dept. of Electrical & Electronics Engineering. His interest areas are Computer-aided power system analysis and modeling, wide area monitoring protection and control, Power Electronics, FACTS etc.

T.Santhosh Kumar received the B.Tech. degree in Electrical and Electronics Engineering from JNTU-Hyderabad, Andhra Pradesh, India in the year 2011, and M.Tech from JNTU Hyderabad, Andhra Pradesh, India in the year 2014. He has teaching experience of Three years in various engineering colleges. He is currently working as Assistant Professor in Holy Mary Institute of Technology and Science, Bogaram (V), R.R. Dist, Hyderabad, Andhra Pradesh, India in the Dept. of Electrical & Electronics Engineering. His interest areas are Power Electronics, FACTS etc.



V.Vijaya Bhaskar completed his M.Tech in the year of 2013 from J.N.T.U Hyderabad. Completed B.Tech from JNTU Hyderabad in 2011 .He has 3 years of Teaching Experience. Presently working as Assistant professor in Holy Mary Institute of Technology & Science, Bogaram, R.R. Dist, Hyderabad, and Telangana, India. His Interested areas are Power Systems, Power Electronics & Drives, FACTS, etc.